

[illegible]



Intumescent Fireproofing Approved Primer List

August 2026

Rustbond	85	1,3,4	1,3,4	1,3,4				1,3,4	1,3,4	1,3,4	
Carbozinc 11 + Carboguard 893 SG	479 336							1	1	1	
Carbozinc 11 + Rustbond	479 85							1,4	1,4	1,4	
Carbozinc 11 HS + Carboguard 893	288 195										1,5

Footnote:

Only primers highlighted in yellow are approved.

1. Designates primers that require a minimum 24 hr. cure @ 70°F before applying intumescent fireproofing.
2. Designates primers that require a minimum 7 day cure @ 70°F before applying intumescent fireproofing.
3. Designates primers that can only be used as tie-coat primers under intumescent fireproofing.
4. Contact Carboline Technical Service before applying Rustbond for exterior applications.
5. Designates primer that is NORSOK tested and compliant.
6. Designates primer that is limited to 75 microns DFT maximum.
7. Designates primer that is limited to 125 microns DFT maximum.
8. For use over galvanized steel applied at 50 microns after suitable surface preparation.
9. Designates primer that is limited to 100 microns DFT maximum.